

DAIKIN ONE+ and ONE TOUCH HOMEOWNER SETTINGS MENU OUTLINE
(based on v3.9 software for VRV and mini/multi-split systems)

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	Level 7	
home screen	mode icon	(see below)					
	room relative humidity						
	room temperature						
	csp and cooler/down icon						
	hsp and warmer/up icon						
	thermostat name field						
	critical error messages	(if any)					
	status messages						
schedule screen	(see below)						
away screen	away csp and hsp						
air quality screen	room temperature						
	outdoor temp						
	outdoor humidity						
	weather forecast						
	circulate air (selection)	off on					
	fan	(same options as fan menu below)					
fan	system mode	auto (cool & heat) -or- master controlled	(The "master controlled" option appears only for VRV systems, and only if another thermostat is master.)				
		cool					
		heat					
		off					
		emergency heat	(if aux heat source available)				
	fan	cooling fan speed	auto	(depends on indoor unit)			
			low	(depends on indoor unit)			
			medium low	(depends on indoor unit)			
			medium	(depends on indoor unit)			
			medium high	(depends on indoor unit)			
		cooling vertical position	high	(depends on indoor unit)			
			oscillate	(depends on indoor unit)			
			fixed	(depends on indoor unit)			
		cooling horizontal position	position	(only VRV, depends on indoor unit)			
			oscillate	(depends on indoor unit)			
			fixed	(depends on indoor unit)			
	schedule	heating fan speed	auto	(depends on indoor unit)			
			low	(depends on indoor unit)			
			medium low	(depends on indoor unit)			
			medium	(depends on indoor unit)			
			medium high	(depends on indoor unit)			
		heating vertical position	high	(depends on indoor unit)			
			oscillate	(depends on indoor unit)			
			fixed	(depends on indoor unit)			
		heating horizontal position	position	(only VRV, depends on indoor unit)			
			oscillate	(depends on indoor unit)			
			fixed	(depends on indoor unit)			
away	away	paused until...	(if schedule paused)				
		on					
		off					
		edit schedule (appears when schedule on)	Sunday Monday Tuesday Wednesday Thursday Friday Saturday	(1st schedule event name)	day (weekday of event)		
				time	(time selection)		
				label	(text entry)		
				action	set temperature		
				temperature	(selection of heat and cool setpoints)		
				(2nd schedule event name)	(same options as 1st schedule event)		
				start time			
				heat setpoint/cool setpoint (up to 6 schedule events)			
		override duration (appears when schedule on)		copy day			
				add event			
				until next event			
				for one hour			
				for two hours			
		on (radio button) off (radio button) away temperatures receive geofencing events (checkbox)		for four hours			
				for eight hours			
display	display	language	english español française				
		degree units	fahrenheit celsius				
		brightness	50 - 100% scale night mode (check box)				
		night mode	from (time selection) to (time selection)				
		use large font (check box)					
		use light bar (check box)					
		screen saver	off blank screen analog clock digital clock				
		screen cleaning	touch screen is disabled for cleaning (30s)				
		lock	Enter a 4-digit PIN...	(number entry)			
		sound	use sound (check box)	(not on the Touch thermostat)			
			Off				

Settings	reminders	(list of installed filters with reminders menu for each)	1 month				
			2 months				
			3 months				
			4 months				
			6 months				
			12 months				
			restart timer	cancel			
				continue			
	date & time	time zone	(list of North America time zones with radio button selection)				
		month/date/year	(selection with spinner, for display only if connected to internet)				
		hour/minute/am or pm	(selection with spinner, for display only if connected to internet)				
		use 24-hour time format (checkbox)					
	wifi	use wifi (checkbox)					
		networks (current network)	network list	legal notices	terms of use	(text)	
				privacy policy	(text)		
				end user license agreement	(text)		
				decline			
				accept			
				(password text box)	(if protected network)		
				show password (checkbox)			
				advanced settings	use dhcp (checkbox)		
		internet connected (or) search again		connect per agreed terms (and) Done	(initiates connection to wifi network)		
	account	Daikin One Cloud connected (checkbox)					
		legal notices	terms of use	(text)			
			privacy policy	(text)			
			end user license agreement	(text)			
	air quality	restart thermostat (if internet but no cloud)					
		(6-digit account code if app not connected)					
	humidity	(account email if app connected)					
		reset registration (if app connected)	cancel				
	energy		continue				
		air quality	circulate air	off			
				on			
	thermostat	humidity	target humidity	humidify if less than (25% - 65%)	(5% increments)		
				dehumidify if more than (35% - 75%)	(5% increments)		
			overcool to dehumidify	Overcooling allowed to dehumidify: 0°F to 3°F (0°C to 1.5°C)	(1°F or 0.5°C increments)		
				Temperature setpoint deadband: 2°F to 9°F (1°C to 5°C)	(1°F or 0.5°C increments)		
		energy	demand response	use demand response (checkbox)	(only functional with local utility support)		
				When demand response signal is received:	offset temperature setpoints		
					use fixed temperature setpoints		
				setpoint offsets	Offset heat setpoints by this value: (-1°F to -7°F)		
					Offset cool setpoints by this value: (1°F to 7°F)		
				event setpoint limits	(50°F to 90°F)		
				enable energy pricing (checkbox)			
				price trigger (if checkbox above)	(\$0.00 to \$9.99)		
	equipment	thermostat	name	main room			
				upstairs			
				downstairs			
				hallway			
				bedroom			
				kitchen			
				other			
				other name (if other selected)	(text entry)		
		remote sensors	model ONEPLUS				
			software version (x.x.x format)				
			wifi address (x:x:x:x:x:x format)				
			thermostat ID (DKN...)	(2D barcode of DKN number for cloud commissioning)			
	equipment			dismiss			
			restart thermostat	cancel			
				continue			
			check for update	software update found (or) no update available--dismiss			
	remote sensors	COMMUNICATING EQUIPMENT:					
		indoor unit	(unit description)				
			model #				
			serial #				
		outdoor unit	(unit description)				
			model #				
			serial #				
		ADDITIONAL EQUIPMENT:					
			include thermostat (temp/hum values)	(check box)			
				sensor name	(text entry)		
				sensor type	surface mount		
				signal strength (acceptable, marginal, or low)	(bar displaying signal strength)		
				cancel			

			save		
		(sensor name) (temp/hum values)	(similar, up to 8 sensors)		
	air quality sensor	(if installed)			
	aux heat source	(if installed)			
	filter box	(if installed)			
	HEPA filter	(if installed)			
	standard filter	(if installed)			
	dehumidifier	(if installed)			
	humidifier	(if installed)			
	VRV IDU sensor	(only VRV systems, if installed)			
	Daikin Support				
support	Daikin Dealer				
		no access			
	cloud services	view only			
		adjust settings			
dealer edit	cancel	(i)	(4 digit pin for thermostat)		
	continue	4 digit code (text entry)			
		unlock thermostat (or)			
		done	(entry into commissioning screens)		